



Republic of the Philippines
Department of the Interior and Local Government
Regional Office V

**PROCUREMENT OF GENERATOR SETS FOR USE IN THE PROVINCIAL OFFICES OF DILG V IN
THE CALENDAR YEAR OF 2022**

SUPPLEMENTAL BID BULLETIN No. 2

In consideration of the queries, clarifications, recommendations, and suggestions, the DILG REGIONAL OFFICE V hereby include the following responses and information from the various DILG V Provincial Offices regarding the procurement of Generator Sets, pursuant to Sec. 22.5 of the IRR of R. A. 9184:

Masbate:

1. Distance of Line/Wire Connection Between Generator and Office Building: **50 Meters**
2. Existing Current Generator: **Single Phase**
3. **No Automatic Transfer Switch (ATS)**
4. **No Generator Set Pad**

Sorsogon:

1. Distance of Line/Wire Connection Between Generator and Office Building: **12 Meters**
2. Existing Current Generator: **Current Generator is Single Phase and 6.5HP only**
3. **No Automatic Transfer Switch (ATS)**
4. **No Generator Set Pad and Gen Set Room for the existing generator**
5. Additional Requirements: A higher rating Generator Set with Generator Room for the Provincial Office of Sorsogon (Total Load of the Building is 106.67 AMP)

Camarines Sur:

1. Distance of Line/Wire Connection Between Generator and Office Building: **50 Meters**
2. Existing Current Generator: **None**
3. **No Automatic Transfer Switch (ATS)**
4. **No Generator Set Pad**

“Matino, Mahusay at Maaasahan”

Rizal St., Legazpi City

(052) 4801484; 4801486 (052) 4804023

<http://region5.dilg.gov.ph>

region5dilg@gmail.com



Republic of the Philippines
Department of the Interior and Local Government
Regional Office V

Camarines Norte:

1. Distance of Line/Wire Connection Between Generator and Office Building: **50 Meters**
2. Existing Current Generator: **Single Phase**
3. **No Automatic Transfer Switch (ATS)**
4. **No Generator Set Pad**

Catanduanes:

1. Distance of Line/Wire Connection Between Generator and Office Building: **20 Meters**
2. Existing Current Generator: **None**
3. **No Automatic Transfer Switch (ATS)**
4. **No Generator Set Pad**

Albay:

No response was given.

The BAC is also reminding prospective bidders that the Last Day of Submission of Bids and Bid Opening has been moved to November 25, 2021. Online attendance to the Bid Opening may be participated through Google Meet. Below are the meeting details for interested bidders:

Google Meet joining info

Time: Thursday, November 25 · 2:00 – 4:00pm

Google Meet Code: **xuc-vzjn-unz**

All provisions of the bidding document that are affected by this newly issued bid bulletin are deemed modified / amended / revised. The announcement made herein shall be considered an integral part of the Bidding Document.



ALFREDO L. SALLAN

Chairperson, Bids and Awards Committee

“Matino, Mahusay at Maaasahan”

Rizal St., Legazpi City

(052) 4801484; 4801486 (052) 4804023

<http://region5.dilg.gov.ph>

region5dilg@gmail.com